




Pipe Guides

SUBMITTAL

MODEL SELECTION CHART

PIPE SIZE INCHES	INSULATION THICKNESS				
	1"	1 1/2"	2"	2 1/2"	3"
1/2	23	23	24	25	26
3/4	23	24	25	26	26
1	23	24	25	26	26
1 1/4	23	24	25	26	26
1 1/2	24	24	25	26	26
2	24	25	26	26	27
2 1/2	25	25	26	26	27
3	25	26	26	27	27
4	26	26	27	27	28
5	27	27	27	28	28
6	27	27	28	28	29
8	28	28	29	30	30
10	30	30	30	31	31
12	31	31	31	32	32



MODEL	A	B	C	D	E	F	G	MAX MOVEMENT
23	3 1/2"	5 3/4"	5 7/8"	4 1/4"	5/8"	1 3/4"	3"	4"
24	4	6 3/4"	7"	4 1/2"	5/8"	1 3/4"	3"	4"
25	4 3/8"	7 5/8"	8"	5 1/4"	5/8"	1 3/4"	3"	4"
26	5 1/4"	9 1/2"	10 3/8"	6 1/4"	5/8"	1 3/4"	3"	4"
27	6 1/4"	11 5/8"	12 1/2"	7 1/4"	5/8"	2 3/4"	4"	6"
28	7 1/4"	13 5/8"	14 1/2"	8 1/4"	5/8"	2 3/4"	4"	6"
29	8	15	15 3/4"	10"	3/4"	4"	6"	8"
30	9	17	17 3/4"	11"	3/4"	4"	6"	8"
31	9 3/4"	18 3/4"	20 1/8"	12"	3/4"	4"	6"	8"
32	11 1/8"	21 1/8"	20 1/8"	13 1/2"	7/8"	4"	6"	8"

Job _____

Contractor _____

Engineer _____

Representative _____

Order No. _____ Date _____

Submitted by _____

Approved by _____ Date _____

Tag _____



287 South Sante Fe Drive
 Denver, Colorado 80223
 Phone (303) 698-9988
 www.thermotechdenver.com

Pipe Guides